



CUSTOMER POLICY 211

Net Metering Policy for Customer-Generators Sized 25 kW or smaller

1. OBJECTIVE

To set forth a policy for the interconnection and net metering of renewable energy generation in accordance with Nebraska's Revised statutes 70-2001 to 70-2005, or as amended. Net metering is available to eligible customers whose electric service is supplied by Dawson Public Power District (also referred to as the District).

2. DEFINITION

Customer-generator: The party that is in control of the qualified facility, as defined in Nebraska Statute 70-2002 (7), that is located on premises owned, leased, or otherwise controlled by the party.

Interconnection Application: Form to be used by the customer generator to submit a formal request for interconnection to the distribution system. Application must be received at least 60 days prior to installation (reference Nebraska Revised Statutes 70-2004 (2)).

Interconnection Agreement: The written agreement between the customer-generator and the District that outlines the requirements and obligations of both the customer-generator and the District.

Net metering: The measured difference between the electricity supplied to a customer-generator by the District and the electricity generated by the customer-generator and delivered to the District at the same point of interconnection.

Rated generating capacity: The maximum continuous kilowatt (kW) AC generation capacity at the generation source as described by the manufacturer. If a maximum continuous kW AC generation capacity is not provided, a peak value will be used.

3. ELIGIBILITY

Applicable to customer-generators as follows:

1. Customer-generator has a total aggregate nameplate generating capacity, from single or multiple generators of twenty-five kilowatts (25KW) alternating current (AC) or less and be a Qualified Facility as described in Nebraska Statute 70-2002 (7).
 - a. The generator is intended to offset part or all of the customer-generator's requirements for electric energy (measured in kilowatt hours) at the same location and not at another location.

- i. If available, the District can provide historical usage and demand data to the customer-generator which may be used to properly size the generator(s).
2. The customer-generator must be a customer in good standing with Dawson Public Power District.
3. The customer-generator must complete, sign and return to the District an Interconnection Application no less than 60 days prior to installation with the distribution system operated by the District.
 - a. The customer-generator must meet all safety and performance requirements of the District and all applicable regulations, interconnection, and reliability standards established by the National Electrical Code, the National Electrical Safety Code, the Institute of Electrical and Electronics Engineers, and the Underwriters Laboratories. These requirements include being equipped to automatically isolate the qualified facility from the electric system in the event of an electrical power outage or other conditions where the line is de-energized.
4. The customer-generator shall enter into a written Interconnection Agreement with the District.
5. The customer-generator shall pay the District for all costs incurred by the District for equipment or services required for interconnection of the qualified facility unless otherwise provided for in statute.
6. Before the customer-generator account is placed on the Net Metering Rider Rate (NMRR) they must meet with District personnel to complete the Verification Test Procedure.
 - a. The Verification Test Procedure ensures that the customer-generator and District personnel are familiar with the way the generator will shut down if there is power loss on the District's grid. During testing, the District will verify the installation of the disconnect switch required by the District.

A single meter or metering system shall be employed to read the flow of energy in two directions. Energy use and excess energy generated will be recorded by the meter. They will be netted for billing purposes. Additional meters may be installed at the expense of the District and may be used to generate data on net metering and not for billing purposes.

In months when the customer generates more electricity than is consumed, all such excess energy is expressed as a monetary credit as calculated using Dawson Public Power District's Net Metering Service Rider Rate. See NMRR for the Retail Billing Procedure.

A customer receiving service under this policy will be subject to the same retail rate as those who are not generators. Customer-generators served under this rate remain responsible for all charges from their normal rate schedule including monthly minimum charges, distribution charges, customer charges, meter charges, facilities charges, demand charges and surcharges.

At a time when the total generating capacity of all customer-generators using net metering is equal to or in excess of one percent of the rated capacity necessary to meet the District's average aggregate customer monthly peak demand forecast for the calendar year, the District may deny net metering service to additional customer-generators.

Customer-generator usage and sales shall be reviewed at the end of the billing year. Net generation should not exceed load as measured in kilowatt hours. If generation is exceeding the load, a notice will be mailed to the customer. The notice shall explain the consequence of over generation will be a change to the simultaneous buy-sell rate. If the generation continues to exceed the load the next consecutive billing year, the account shall be reclassified as local generation with the intent to sell power, rather than offset loads. Reclassification of the account will require a change to the Simultaneous Buy-Sell Rate. Changes to the metering may result in additional charges to the customer-generator.

If a customer owned generator creates power quality issues for the District and/or other electric consumers, the District reserves the right to disconnect the generator until the customer-generator can take corrective measures. This is outlined in the District's General Rules & Regulations.